

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

Country Haven Mobile Home Park
Public Water Supply Name

0170027

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☒ Advertisement in local paper (attach copy of advertisement) *Desoto Times*
☐ On water bills (attach copy of bill)
☐ Email message (MUST Email the message to the address below)
☒ Other *Posted in Lobby at Country Haven Park office*

Date(s) customers were informed: */ / , / / , / /*

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: *06 / 16 / 15*

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: */ /*

- ☐ As a URL (Provide URL _____)
☐ As an attachment
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: *Desoto Times*

Date Published: *06 / 16 / 15* *Posted in Country Haven Park office*

CCR was posted in public places. *(Attach list of locations)*

Date Posted: *06 / 16 / 15*

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Richard W. Bee Owner Representative
Name/Title (President, Mayor, Owner, etc.)

06 / 16 / 15 Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:
water.reports@msdh.ms.gov

Country Haven Mobile Home Park ✓

1151 Hwy 51 N • Nesbit, MS 38651

PWSID# 0170027

Water Quality Report 2014



Prepared by:

Mitchell Technical Services, Inc
325 West McKnight
Murfreesboro, TN 37129



gc

IS MY WATER SAFE ? Last year your tap water met all monitored U.S. Environmental Protection Agency (EPA) and state drinking water health standards. We vigilantly safeguard the water supply and we are proud to report that our system meets all monitored federal and state requirements.

REPORT AVAILABILITY This report is not mailed to the residents; however, it is published annually in the local paper and is also posted in the central office on the bulletin board for review.

DO I NEED TO TAKE SPECIAL PRECAUTIONS? Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

WHERE DOES MY WATER COME FROM? Our water comes from two wells over 200 feet deep, which draw ground water from the Sparta Sand Aquifer.

SOURCE WATER ASSESSMENT AND ITS AVAILABILITY. Our source water assessment has been completed by the Mississippi State Department of Health. The results of the report are available at:

<http://landandwater.deq.ms.gov/swap/reports/report.aspx?id=0170027>

The susceptibility ranking of each of our wells was Moderate

WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

HOW CAN I GET INVOLVED? We encourage all customers who have any concerns or questions to contact our office.

OTHER INFORMATION: You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address:

<http://www.msdh.state.us/watersupply/index.htm>.

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" may be obtained.

Certified Operator:	Bryan Lane	Phone	(662) 562.5314
Operations Firm:	MTS, Inc.	Fax	(662) 562.5314
Emergency Contact :	(662) 429.9626		

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Important Drinking Water Definitions:

ND: **Non-Detects:** Laboratory analysis indicates that the constituent is not present.

MCLG: **Maximum Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: **Maximum Contaminant Level:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Units Description:

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

ppm: parts per million, or mg/l: milligrams per liter

ppb: parts per billion, or µg/l : micrograms per liter

Nitrates

Contaminant	MCL	Your Water
Sample Date	MCLG	Violation Y / N
Nitrate 01/27/2014	10 ppm	< 0.08 ppm N
Nitrite 01/27/2014	1 ppm	< 0.02 ppm N
Nitrate-Nitrite 01/27/2014	10 ppm	< 0.1 ppm N

Inorganic Chemicals

Contaminant Sample Date	MCL MCLG	Your Water Violation Y/N	Likely Source of Contaminant
Barium (ppm) 04/14/2014	2.0 2.0	0.0314 N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (ppm) 04/14/2014	0.1 0.1	0.0021 N	Discharge from steel and pulp mills; erosion of natural deposits
Copper (ppm) 06/23-25/2014	1.3 1.3	0.2 N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
Lead (ppm) 06/23-25/2014	0.015 0.015	0.003 N	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfectants & Disinfectant Byproducts

Contaminant Sample Date	MRDL RANGE	QTR AVG Violation Y/N
Maximum Residual Disinfectant Level (MRDL) January 2014 - December 2014	0.34 mg/L 1.54 mg/L	1.10 mg/L N

Contaminant Sample Date	MCL MCLG	Your Water Violation Y / N
Haloacetic Acids (HAA5) 07/10/12	0.060 ppm	4.0 ppb N
Total Trihalomethane (TTHM) 09/03/2014	0.080 ppm	< 4.0 ppb N

Cyanide

Contaminant	MCL	Your Water
Sample Date	MCLG	Violation Y / N
Cyanide	0.2 ppm	< 0.015 ppm
07/14/2014		N

During a sanitary survey conducted on June 6, 2011, the Mississippi State Department of Health cited the following significant deficiency(s):

Inadequate internal cleaning / maintenance of storage tanks.

Corrective Actions: MSDH is currently working with this system to return them to compliance since the expiration of the compliance deadline. It is anticipated we will be returned to compliance by September 30, 2015.

Significant
Deficiencies

2015 JUN 18 PM 11: 50

Advertising Invoice

Desoto Times-Tribune/CLICK Magazine 1/1
2015 JUN 18 PM 11: 50

PO Box 100
Hernando MS 38632

Phone: 662-429-6397

Fax: 662-429-5229

URL: www.desototimes.com

Roy
Country Haven Mobile Home Park
1151 Hwy 51 N (Office)
Nesbit, MS 38651

Acct. #: 00003405
Phone #: (662)429-9626
Post Date: 06/16/2015
Due Date: 07/13/2015
Invoice #: 300080821

Ad #	Pub.	Start	Stop	Description	Cols.	Inch	Days	Amount
00037683	01	06/16/2015	06/16/2015	PN: Water Quality Report Proof Of Publication	4	16.00	1	652.16 3.00

Include Ad # and Account # with Payment
Pub Codes: 01-Weekday; 02-Weekend; 40-Click; 20-Online Advertising

Please return a copy with payment

Total Due 655.16

AFFP

PN: Water Quality Report

Affidavit of Publication

DESOTO TIMES-TRIBUNE

STATE OF MS }

SS

COUNTY OF DESOTO }

Diane Smith, being duly sworn, says:

That she is a Clerk of the DESOTO TIMES-TRIBUNE, a newspaper of general circulation in said county, published in Hernando, DeSoto County, MS; that the publication, a copy of which is printed hereon, was published in the said newspaper on the following dates:

June 16, 2015

That said newspaper was regularly issued and circulated on those dates.

SIGNED:

Clerk

Subscribed to and sworn to me this 16th day of June 2015.

JUDY HAYES, Notary, DeSoto County, MS

My commission expires: October 01, 2017

0003405 00037683

Roy
Country Haven Mobile Home Park
1151 Hwy 51 N (Office)
Nesbit, MS 38651



2015 JUN 18 PM 11:50

Country Haven Mobile Home Park

1151 HWY 51 N | Nesbit, MS 38651

PWSID# 0170027

Water Quality Report

2014

IS MY WATER SAFE?

Last year your tap water met all monitored U.S. Environmental Protection Agency (EPA) and state drinking water health standards. We vigilantly safeguard the water supply and we are proud to report that our system meets all monitored federal and state requirements.

REPORT AVAILABILITY

This report is not mailed to the residents, however, it is published annually in the local paper and is also posted in the central office on the bulletin board for review.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

WHERE DOES MY WATER COME FROM?

Our water comes from two wells over 200 feet deep, which draw ground water from the Sparta Sand Aquifer.

SOURCE WATER ASSESSMENT AND ITS AVAILABILITY

Our source water assessment has been completed by the Mississippi State Department of Health. The results of the reports are available at:

<http://standardswater.dsh.ms.gov/mswp/reports/report.aspx?id=0170027>

The susceptibility ranking of each of our wells was **Moderate**.

WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

HOW CAN I GET INVOLVED?

We encourage all customers who have any concerns or questions to contact our office.

OTHER INFORMATION:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address:

<http://www.msh.state.ms.us/water/waterindex.htm>

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" may be obtained.

Certified Operator: Bryan Lane
Operations Firm: MTS, Inc.
Emergency Contact: (901) 413-7714

Phone: (662) 562-5314
Fax: (662) 562-5314

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of the report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data represented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Important Drinking Water Definitions:

ND: Non-Detects: Laboratory analysis indicates that the constituent is not present.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG allows for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as low as the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Units Description:

NA: Not applicable
NR: Not reported

ND: Not detected
MNR: Monitoring not required, but recommended.

ppm: parts per million, or mg/L: milligrams per liter
ppb: parts per billion, or ug/L: micrograms per liter

NITRATES

Contaminant	MCL	Your Water
Sample Date	MCLG	Violations Y/N
NITRATE	10 ppm	< 0.08 ppm
01/27/2014		N
NITRATE	1 ppm	< 0.02 ppm
01/27/2014		N
NITRATE - NITRATE	10 ppm	< 0.1 ppm
01/27/2014		N

INORGANIC CHEMICALS

Contaminant	MCL	Your Water	Likely Source of Contaminant
Sample Date	MCLG	Violations Y/N	
Barium (ppm)	2.0	0.0314	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
04/14/2014	2.0	N	
Chromium (ppm)	0.1	0.0021	Discharge from steel and pulp mills; erosion of natural deposits
04/14/2014	0.1	N	
Copper (ppm)	1.3	0.0	Breakdown of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
07/14/2011	1.3	N	
Lead (ppm)	15	2	Corrosion of household plumbing systems; Erosion of natural deposits
07/14/2011	15	N	

Disinfectants & Disinfectant Byproducts

Contaminant	MRDL	QTR AVG
Sample Date	RANGE	Violations Y/N